

TABLE 2-1: Cost Estimates for Post-Combustion SO<sub>x</sub> and NO<sub>x</sub> Reduction Measures for the Utility and Industrial Sectors<sup>7</sup>

Technology	Capital Costs (US\$/kW)		Variable O&M Costs (US cents/kWh)		Total O&M Costs (US cents/kWh)	
	New	Retrofit	New	Retrofit	New	Retrofit
Pre-ESP Sorbent Injection	60 - 120					
Post-ESP Sorbent Injection	100 - 200					
Wet Scrubbers	120 - 210	150 - 270	.13 - .32	.15 - .33	.74 - 1.3	.66 - 1.2
Dry Scrubbers	110 - 165	140 - 210	.21 - .32	.21 - .32	.74 - 1.1	.60 - .90
Selective non-catalytic red.	5 - 10	10 - 20			.1 - .2	
Selective catalytic reduction	50 - 150				.4 - .8	
Combined NO <sub>x</sub> /SO <sub>x</sub> Control	300 - 400				1.0 - 1.8	